



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx LCIE 13.0049X issue No.: 1

Status: **Current**

Date of Issue: **2014-10-21**

Page 1 of 4

Certificate history:

Issue No. 1 (2014-10-21)  
Issue No. 0 (2013-11-15)

Applicant: **SATAM**  
Avenue de Verdun  
14700 FALAISE  
France

Electrical Apparatus: **Calculator-Indicator - Type : CM/HM or HM**  
Optional accessory:

Type of Protection: **Ex d[ia]ia and Ex d[ia]**

Marking: **SATAM**  
Address: ...  
Type CM/HM : Ex d[ia] Ga]ia IIB T4 GbGa  
Type HM : Ex d[ia] Ga] IIB T4 Gb  
IECEx LCIE 13.0049X  
IS parameters :  $U_0 = \dots V$ ,  $I_0 = \dots A$ ,  $C_0 = \dots F$ ,  $L_0 = \dots H$  (see attachment)

Approved for issue on behalf of the IECEx  
Certification Body:

Julien GAUTHIER

Position:

Certification Officer

Signature:  
(for printed version)

Date:

2014-10-21

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://Official IECEx Website).

Certificate issued by:

**Laboratoire Central des Industries Electriques (LCIE)**  
33 Avenue du General Leclerc  
FR-92260 Fontenay-aux-Roses  
France

Documents relative to LCIE certification activities (Certificates, QARs, ExTRs) can be registered under the references "LCI" or "LCIE".



LCIE



# IECEx Certificate of Conformity

Certificate No.: IECEx LCIE 13.0049X

Date of Issue: 2014-10-21

Issue No.: 1

Page 2 of 4

Manufacturer: **SATAM**  
Avenue de Verdun  
14700 FALAISE  
France

## Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition: 6.0

**IEC 60079-1 : 2007-04** Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition: 6

**IEC 60079-11 : 2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition: 6.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

### Test Report:

FR/LCIE/ExTR13.0043/00

FR/LCIE/ExTR13.0043/01

### Quality Assessment Report:

FR/LCI/QAR11.0016/02



# IECEx Certificate of Conformity

Certificate No.: IECEx LCIE 13.0049X

Date of Issue: 2014-10-21

Issue No.: 1

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

This apparatus allows loading of hydrocarbon products for depot or truck applications.

Type CM/HM : the apparatus is formed of an electronic flameproof module HM connected to an electronic intrinsically safe enclosure CM. The front side of the enclosure CM can be equipped or not with a display, a keyboard, switches.

Type HM: the apparatus is formed of an electronic flameproof module HM

The apparatus exists in two versions :

- depot application
- truck application

Marking : see attachment

Electrical parameters : see attachment.

#### Routine verifications and tests :

- Zener barrier :

According to clause 11.1.1. of standard EN 60079-11, each apparatus shall be submitted to a test to check correct operation of each barrier component and the resistance of any fuse.

- Flameproof enclosure :

The apparatus is exempt of routine test.

### CONDITIONS OF CERTIFICATION: YES as shown below:

The intrinsic safety terminal blocks can be only connected to intrinsically safe certified apparatus or according to clause 5.7 of IEC 60079-11 Ed6.0 standards. These combinations must be compatible as regard intrinsic safety rules.

Operating ambiente temperature : -20°C to +55°C.



# IECEx Certificate of Conformity

Certificate No.: IECEx LCIE 13.0049X

Date of Issue: 2014-10-21

Issue No.: 1

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Initial issue (15-11-2013) :

Certification according to IEC 60079-0 Ed 6.0, IEC 60079-1 Ed 6 and IEC 60079-11 Ed 6.0.

Issue 1 :

Design modification of Ex d box in order to avoid unit pressure tests.

SATAM manufactures its own zener barrier (identical to the previous one).

Routine test modification.

Annex: LCIE 13.0049X-Issue 01 -attachment 01.pdf



# IECEx LCIE 13.0049 issue 01 Attachment n°01



LCIE

## MARKING :

### Type : CM/HM

SATAM

Address : ....

Type : CM/HM

Serial number : .....

Year of construction : .....

Ex d [ia Ga] ia IIB T4 Gb Ga

IECEx LCIE 13.0049 X

$U_o \leq \dots V$ ,  $I_o \leq \dots mA$ ,  $P_o \leq \dots W$ ,  $C_o \leq \dots \mu F$ ,  $L_o \leq \dots \mu H$

$U_i \leq \dots V$ ,  $I_i \leq \dots mA$ ,  $P_i \leq \dots W$ ,  $C_i \leq \dots \mu F$ ,  $L_i \leq \dots \mu H$

(completed with the electrical parameters)

On the part "d" :

WARNING-DO NOT OPEN WHEN ENERGIZED

WARNING- DO NOT OPEN IN PRESENCE OF EXPLOSIVE ATMOSPHERE

### Type : HM

SATAM Address : .....

Type : HM

Serial number : .....

Year of construction : .....

Ex d [ia Ga] IIB T4 Gb

IECEx LCIE 13.0049 X

$U_o \leq \dots V$ ,  $I_o \leq \dots mA$ ,  $P_o \leq \dots W$ ,  $C_o \leq \dots \mu F$ ,  $L_o \leq \dots \mu H$  (completed with the electrical parameters) WARNING-

DO NOT OPEN WHEN ENERGIZED

WARNING- DO NOT OPEN IN PRESENCE OF EXPLOSIVE ATMOSPHERE

## ELECTRICAL PARAMETERS :

$U_m$  : 230VAc or 24VDC

### Type CM/HM :

Board PM :

Terminal blocks		Electrical parameters
J1	board type PLS12V_NM	$U_o \leq 10V, I_o \leq 10mA, P_o \leq 25mW, C_o \leq 20\mu F, L_o \leq 1H$
	board type PLS12V_FH71	$U_o \leq 16V, I_o \leq 60mA, P_o \leq 240mW, C_o \leq 2,9\mu F, L_o \leq 4mH$
	board type PLS12V_HF_TTL board type PLS12_HF_CO	Terminals J1.1, J1.4, J1.7, J1.10 $U_o \leq 16V, I_o \leq 106mA, P_o \leq 430mW, C_o \leq 2,9\mu F, L_o \leq 2mH$
		Terminals J1.2, J1.5, J1.8, J1.11 $U_o \leq 16V, I_o \leq 2mA, P_o \leq 8mW, C_o \leq 2,9\mu F, L_o \leq 1H$
J2		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J3, J4, J9		$U_o \leq 7,9V, I_o \leq 272mA, P_o \leq 540mW, C_o \leq 115\mu F, L_o \leq 3mH$
J8		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J6,J7		$U_o/U_i \leq 7,9V, I_o/I_i \leq 272mA, P_o/P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
J5		$U_i \leq 7,9V, I_i \leq 272mA, P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
Commutation board 2xPT100		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
CN4,CN5		
Namur board		$U_o \leq 9,9V, I_o \leq 272mA, P_o \leq 670mW, C_o \leq 109\mu F, L_o \leq 3mH$
Anti over flow board		$U_o \leq 11,8V, I_o \leq 174mA, P_o \leq 510mW, C_o \leq 6,5\mu F, L_o \leq 3mH$

This Annex is valid only in combination with certificate IECEx LCIE 13.0049 issue 01 and may only be reproduced in its entirety and without any change.



Board UI :

Terminal blocks	Electrical parameters
J1, J3	$U_o/U_i \leq 7,9V$ , $I_o/I_i \leq 272mA$ , $P_o/P_i \leq 540mW$
J2, J5	$U_i \leq 7,9V$ , $I_i \leq 272mA$ , $P_i \leq 540mW$ , $C_i \approx 0$ , $L_i \approx 0$

**Type HM :**

Board PM :


Terminal blocks		Electrical parameters
J1	board type PLS12V_NM	$U_o \leq 10V, I_o \leq 10mA, P_o \leq 25mW, C_o \leq 20\mu F, L_o \leq 1H$
	board type PLS12V_FH71	$U_o \leq 16V, I_o \leq 60mA, P_o \leq 240mW, C_o \leq 2,9 F, L_o \leq 4mH$
	board type PLS12V_HF_TTL board type PLS12_HF_CO	Terminals J1.1, J1.4, J1.7, J1.10 $U_o \leq 16V, I_o \leq 106mA, P_o \leq 430mW, C_o \leq 2,9\mu F, L_o \leq 2mH$
		Terminals J1.2, J1.5, J1.8, J1.11 $U_o \leq 16V, I_o \leq 2mA, P_o \leq 8mW, C_o \leq 2,9\mu F, L_o \leq 1H$
J2		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J3, J4, J9		$U_o \leq 7,9V, I_o \leq 272mA, P_o \leq 540mW, C_o \leq 115\mu F, L_o \leq 3mH$
J8		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J6,J7		$U_o/U_i \leq 7,9V, I_o/I_i \leq 272mA, P_o/P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
J5		$U_i \leq 7,9V, I_i \leq 272mA, P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
Commutation board 2xPT100 CN4,CN5		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
Namur board		$U_o \leq 9,9V, I_o \leq 272mA, P_o \leq 670mW, C_o \leq 109\mu F, L_o \leq 3mH$
Anti over flow board		$U_o \leq 11,8V, I_o \leq 174mA, P_o \leq 510mW, C_o \leq 6,5\mu F, L_o \leq 3mH$



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	IECEx LCIE 13.0049X	issue No.:0	Certificate history:
Status:	Current		
Date of Issue:	2013-11-15	Page 1 of 3	
Applicant:	<b>SATAM</b> Avenue de Verdun 14700 FALAISE France		
Electrical Apparatus: Optional accessory:	<b>Calculator-Indicator</b>		
Type of Protection:	<b>d[ia]ia and d[ia]</b>		
Marking:	SATAM Address Type CM/HM : Ex d[ia Ga]ia IIB T4 GbGa Type HM : Ex d[ia Ga] IIB T4 Gb IECEx LCIE 13.0049X (see attachment)		
Approved for issue on behalf of the IECEx Certification Body:	Julien Gauthier		
Position:	Certification Officer		
Signature: (for printed version)			
Date:	2013-11-15		

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**Laboratoire Central des Industries Electriques (LCIE)**

**33 Avenue du General Leclerc**

**FR-92260 Fontenay-aux-Roses**

**France**

**Documents relative to LCIE certification activities (Certificates,  
QARs, ExTRs) can be registered under the references "LCI" or  
"LCIE".**





# IECEx Certificate of Conformity

Certificate No.: IECEx LCIE 13.0049X

Date of Issue: 2013-11-15

Issue No.: 0

Page 2 of 3

Manufacturer: **SATAM**  
Avenue de Verdun  
14700 FALAISE  
France

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 0: General requirements
<b>IEC 60079-1 : 2007-04</b> Edition: 6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-11 : 2011</b> Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:  
[FR/LCIE/ExTR13.0043/00](#)

Quality Assessment Report:

[FR/LCI/QAR11.0016/00](#)

[FR/LCI/QAR11.0016/01](#)

[FR/LCI/QAR11.0016/02](#)





# IECEx Certificate of Conformity

Certificate No.: IECEx LCIE 13.0049X

Date of Issue: 2013-11-15

Issue No.: 0

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

This apparatus allows loading of hydrocarbon products for depot or truck applications.

Type CM/HM : the apparatus is formed of an electronic flameproof module HM connected to an electronic intrinsically safe enclosure CM. The front side of the enclosure CM can be equipped or not with a display, a keyboard, switches.

Type HM: the apparatus is formed of an electronic flameproof module HM

The apparatus exists in two versions :

- depot application

- truck application

Marking : see attachment

Electrical parameters : see attachment.

### CONDITIONS OF CERTIFICATION: YES as shown below:

The intrinsic safety terminal blocks can be only connected to intrinsically safe certified apparatus or according to clause 5.7 of IEC 60079-11 Ed6.0 standards. These combinations must be compatible as regard intrinsic safety rules.

Operating ambiante temperature : -20°C to +55°C.

Routine test :

Each HM module shall be submitted to an overpressure test at 9,1 bars during at least 10s.



# IECEx LCIE 13.0049 X issue 0 Attachment n°01



## MARKING :

### Type : CM/HM

SATAM

Address : .....

Type : CM/HM

Serial number : .....

Year of construction : .....

Ex d [ia Ga] ia IIB T4 Gb Ga

IECEx LCIE 13.0049 X

$U_o \leq \dots V$ ,  $I_o \leq \dots mA$ ,  $P_o \leq \dots W$ ,  $C_o \leq \dots \mu F$ ,  $L_o \leq \dots \mu H$

$U_i \leq \dots V$ ,  $I_i \leq \dots mA$ ,  $P_i \leq \dots W$ ,  $C_i \leq \dots \mu F$ ,  $L_i \leq \dots \mu H$

(completed with the electrical parameters)

On the part "d" :

WARNING-DO NOT OPEN WHEN ENERGIZED

WARNING- DO NOT OPEN IN PRESENCE OF EXPLOSIVE ATMOSPHERE

### Type : HM

SATAM

Address : .....

Type : HM

Serial number : .....

Year of construction : .....

Ex d [ia Ga] IIB T4 Gb

IECEx LCIE 13.0049 X

$U_o \leq \dots V$ ,  $I_o \leq \dots mA$ ,  $P_o \leq \dots W$ ,  $C_o \leq \dots \mu F$ ,  $L_o \leq \dots \mu H$  (completed with the electrical parameters)

WARNING-DO NOT OPEN WHEN ENERGIZED

WARNING- DO NOT OPEN IN PRESENCE OF EXPLOSIVE ATMOSPHERE

## ELECTRICAL PARAMETERS :

$U_m$  : 230VAc or 24VDC

### Type CM/HM :

Board PM :

Terminal blocks		Electrical parameters
J1	board type PLS12V_NM	$U_o \leq 10V$ , $I_o \leq 10mA$ , $P_o \leq 25mW$ , $C_o \leq 20\mu F$ , $L_o \leq 1H$
	board type PLS12V_FH71	$U_o \leq 16V$ , $I_o \leq 60mA$ , $P_o \leq 240mW$ , $C_o \leq 2,9\mu F$ , $L_o \leq 4mH$
	board type PLS12V_HF_TTL	Terminals J1.1, J1.4, J1.7, J1.10 $U_o \leq 16V$ , $I_o \leq 106mA$ , $P_o \leq 430mW$ , $C_o \leq 2,9\mu F$ , $L_o \leq 2mH$
	board type PLS12_HF_CO	Terminals J1.2, J1.5, J1.8, J1.11 $U_o \leq 16V$ , $I_o \leq 2mA$ , $P_o \leq 8mW$ , $C_o \leq 2,9\mu F$ , $L_o \leq 1H$
J2		$U_o \leq 7,9V$ , $I_o \leq 106mA$ , $P_o \leq 210mW$ , $C_o \leq 115\mu F$ , $L_o \leq 4mH$
J3, J4, J9		$U_o \leq 7,9V$ , $I_o \leq 272mA$ , $P_o \leq 540mW$ , $C_o \leq 115\mu F$ , $L_o \leq 3mH$
J8		$U_o \leq 7,9V$ , $I_o \leq 106mA$ , $P_o \leq 210mW$ , $C_o \leq 115\mu F$ , $L_o \leq 4mH$
J6,J7		$U_o/U_i \leq 7,9V$ , $I_o/I_i \leq 272mA$ , $P_o/P_i \leq 540mW$ , $C_i \approx 0$ , $L_i \approx 0$
J5		$U_i \leq 7,9V$ , $I_i \leq 272mA$ , $P_i \leq 540mW$ , $C_i \approx 0$ , $L_i \approx 0$
Commutation board 2xPT100 CN4,CN5		$U_o \leq 7,9V$ , $I_o \leq 106mA$ , $P_o \leq 210mW$ , $C_o \leq 115\mu F$ , $L_o \leq 4mH$
Namur board		$U_o \leq 9,9V$ , $I_o \leq 272mA$ , $P_o \leq 670mW$ , $C_o \leq 109\mu F$ , $L_o \leq 3mH$
Anti over flow board		$U_o \leq 11,8V$ , $I_o \leq 174mA$ , $P_o \leq 510mW$ , $C_o \leq 6,5\mu F$ , $L_o \leq 3mH$

Board UI :

Terminal blocks	Electrical parameters
J1, J3	$U_o/U_i \leq 7,9V$ , $I_o/I_i \leq 272mA$ , $P_o/P_i \leq 540mW$
J2, J5	$U_i \leq 7,9V$ , $I_i \leq 272mA$ , $P_i \leq 540mW$ , $C_i \approx 0$ , $L_i \approx 0$

This Annex is valid only in combination with certificate IECEx LCIE 13.0049 X issue 0 and may only be reproduced in its entirety and without any change.

**Type HM :**

Board PM :

Terminal blocks		Electrical parameters
J1	board type PLS12V_NM	$U_o \leq 10V, I_o \leq 10mA, P_o \leq 25mW, C_o \leq 20\mu F, L_o \leq 1H$
	board type PLS12V_FH71	$U_o \leq 16V, I_o \leq 60mA, P_o \leq 240mW, C_o \leq 2,9 F, L_o \leq 4mH$
	board type PLS12V_HF_TTL board type PLS12_HF_CO	Terminals J1.1, J1.4, J1.7, J1.10 $U_o \leq 16V, I_o \leq 106mA, P_o \leq 430mW, C_o \leq 2,9\mu F, L_o \leq 2mH$
		Terminals J1.2, J1.5, J1.8, J1.11 $U_o \leq 16V, I_o \leq 2mA, P_o \leq 8mW, C_o \leq 2,9\mu F, L_o \leq 1H$
J2		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J3, J4, J9		$U_o \leq 7,9V, I_o \leq 272mA, P_o \leq 540mW, C_o \leq 115\mu F, L_o \leq 3mH$
J8		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
J6,J7		$U_o/U_i \leq 7,9V, I_o/I_i \leq 272mA, P_o/P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
J5		$U_i \leq 7,9V, I_i \leq 272mA, P_i \leq 540mW, C_i \approx 0, L_i \approx 0$
Commutation board 2xPT100 CN4,CN5		$U_o \leq 7,9V, I_o \leq 106mA, P_o \leq 210mW, C_o \leq 115\mu F, L_o \leq 4mH$
Namur board		$U_o \leq 9,9V, I_o \leq 272mA, P_o \leq 670mW, C_o \leq 109\mu F, L_o \leq 3mH$
Anti over flow board		$U_o \leq 11,8V, I_o \leq 174mA, P_o \leq 510mW, C_o \leq 6,5\mu F, L_o \leq 3mH$